

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220114
Address: 2035 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, June 22, 2023

Corrective Action Required:

2	Misc	DO NOT OCCUPY -water meter to be 14"-18" from meter top to well lid ring. Add gravel in meter pit. -obtain issued lawn irrigation permit -handrail to basement to be 34"-38" from nosing of tread -outlet right of sink for wet bar countertop in basement -address deck post to beam connections(not to code.)
---	------	--

Comments: