

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20222242
Address: 530 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064
Inspected On: Thursday, June 22, 2023
Inspected By: Khanh Nguyen
Expiration Date: 4/12/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Thursday, June 22, 2023

Corrective Action Required:

- | | | |
|---|------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -Approval required from: Field Service Engineer, Planning |
| | | -Underground electrical to light pole piers not inspected. Light poles are not grounded per plan. Provide #6 copper grounding conductor to rod. This grounding conductor must connect to the light pole base terminal. Expose raceway at each LP to verify depth. |
| | | -no trash enclosure is present at time of inspection, verify through planning if trash enclosure is required. |