

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215570
Address: 2361 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ryan Heckman	Passed	Friday, June 23, 2023

Informational:

1 Misc

9-15-22 RH. Sidewalk is formed up and aggregate is placed and compacted.

9-22-22 RH. Sidewalk at storm inlet needs expansion joint around it. Also need to remove panel next to storm inlet and remove old panel connected due to tripping hazard.

6-23-22 RH. Sidewalk meets LS and ADA specification.

Comments: