



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20224767	Date:	June 25, 2023
Project Title:	LEE'S SUMMIT COMMERCE CENTER (LOGISTICS) - ZOETIS	Applicant:	
Location:	1100 NW MAIN ST, Unit:D, LEES SUMMIT, MO 64086		KADEAN CONSTRUCTION 1558 FENPARK DR FENTON, MO 63026
Type of Work:			
Occupancy Group:	S-1		
Description:	TENANT FINISH FOR OFFICE/WAREHOUSE SPACE FOR ANIMAL CARE PRODUCTS	Primary:	(636) 305-0099
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Rejected

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide stamped shop drawings for the alarm system, including contractor information.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.