

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20215090

Address: 3683 NE AKIN DR, Unit:B, LEES SUMMIT, MO 64064  
3683 NE AKIN DR, Unit:C, LEES SUMMIT, MO 64064  
640643683 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Engineering</b>	Nick Scott	Passed	Monday, June 26, 2023

Corrective Action Required:

1	Miscellaneous Correction	6-22-23 DP.
---	--------------------------	-------------

Final Inspection did not pass on our end. Below I will list a punch list of items needed before we can pass final.

- Check all Storm structures private and public. There is debris in some which needs to be cleaned out. Also remove all waddles in Storm structure throats and clean any remaining debris they leave behind. Don't forget the structures along the public road as well.
- Clean up Tops of storm structure lids and remove Porta Potties from top of lids.
- Sweep Streets, a lot of debris and dirt left behind
- Install Stop Signs at both exits. Scott said this shouldn't be a problem.
- Remove equipment and material staged on roads, including any dumpsters
- Paint any PRIVATE Fire Hydrant Bonnets Silver

6-26-23 DP. All punch list items have been complete. Passed.

**Comments:**

