

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223951
Address: 2773 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Shawn Hoffman	Passed	Monday, June 26, 2023

Informational:
1 Misc - UFER ON GARAGE WALL 12" NORTH OF EXTEIRIOR WALL.
3 PIERS DUG FOR DECK (3' DEEP 14"X20")

Comments: