

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212466  
Address: 508 SE DAVID RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Monday, June 26, 2023

Corrective Action Required:

1	Miscellaneous Correction	-Sod to siding must have a 6 inch clearance. -Two exterior splash pads are broken -Sidewalk inspection must pass
---	-----------------------------	--

**Comments:**