

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215090

Address: 3683 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643683 NE AKIN DR, Unit:C, LEES SUMMIT, MO 640643683 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Planning	Hector Soto Jr.	Temporary C of O	Monday, June 26, 2023

Corrective Action Required:

1

PARKING SPACES.

- The six (6) banks of parking spaces located along the main drive loop are not striped. All of the parking areas shall be striped per the approved development plan.

- One the banks of parking spaces requires an ADA parking space per the approved plan. The space shall be marked with a wheelchair symbol; shall have an ADA parking space sign posted at the head of the space; shall also have a sign denoting that the space is van accessible; and shall have the ADA signage mounted a minimum 5' above finished grade, measured to the bottom of the sign.

Comments: