

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220522
Address: 3522 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Tuesday, June 27, 2023

Corrective Action Required:

1	Misc	-Insufficient outlets in the garage -Fire blocking sheet rock required under stairs in basement -GFCI in upstairs hall bathroom did not reset -Remove pressure gauge at sediment trap on gas line and cap off -Conduit loose at A/C disconnect -Seal wall penetration at gas main - Missing caulk above garage sconces
---	------	--

Comments: