

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222626
Address: 2225 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Wednesday, June 28, 2023

Corrective Action Required:

2	Misc	-Missing secondary lock on sliding door to deck -Missing caulk at the top of garage sconces -Missing caulking at sump pump discharge penetration -Address open hole at southwest exterior corner near down spout extension tube
---	------	--

Comments: