

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226253
Address: 3223 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, June 28, 2023

Corrective Action Required:

1	Misc	No further inspections until erosion control in compliance
		<ul style="list-style-type: none">-nail all exterior wall corners to code-secure gas line at fireplace-provide missing truss hangers above bed 2 and bed2 bath-address over notched exterior wall studs in bas-seal wall space to ceiling space bed 4 closet-fire block into furr down left of bed 4 entry-provide proper bonding lug at ufer ground rod-upload engineer letter for I-joist and truss repairs

Comments: