



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110514, Building Permit - Commercial
Address: 695 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, June 17, 2011

Partial Correction
2 MISC

OK TO COVER WHEN READY ACT CEILING AT 101; 103 & 104
AFTER RR VENT FANS ARE WIRED;

Corrective Action Required
3 MISC

ABOVE-CEILING AT 102 NOT COMPLETED & READY FOR
INSPECTION. CEILING SUPPORT WIRES MUST HANG STRAIGHT
(NOT BENT AROUND DUCT,ETC) FROM STRUCTURE ABOVE TO
CEILING GRID BELOW.

Comments: