

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Thursday, June 29, 2023

Corrective Action Required:

1 Misc

Section A:

Line T from 11-9
Line 9 from T to P
Line 11 from Q.5 to T
Line Q.5 from 11 to 12
Line P from 9-12

Building 1, Section B:

-Exterior wall GB and col pads

Footings completed per unapproved details, no approved plans on site
-City stamped approved plans required on site at all times for inspection

Comments: