

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223252
Address: 1067 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, June 29, 2023

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- lower sewer trace wire to grade- Install security screws at front door- Provide a graspable handrail at deck stairs- Provide posts to beam connections at deck per code (post cap, or engineers design)- Label non gfci outlet at sump- Provide cover for attic access- Permanently post address |
|---|------|---|

Comments: