

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20220522
Address: 3522 SE CORBIN DR, LEES SUMMIT, MO 64082
Inspected On: Thursday, June 29, 2023
Inspected By: Kyle Beard
Expiration Date: 7/29/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Temporary C of O	Thursday, June 29, 2023

Corrective Action Required:

2	Misc	Sod to siding must be at least 6 inches in height. Sod must have a 2 percent slope away from the foundation.
---	------	--