

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20212185
Address: 1809 SW SAGE CANYON RD, LEES SUMMIT, MO 64082
Inspected On: Thursday, June 29, 2023
Inspected By: Kyle Beard
Expiration Date: 7/29/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Pending	

Corrective Action Required:

1	Misc	-submit as graded plot plan for review and approval -provide extension at sump pump min 36" discharge from foundation -provide gravel base at water meter pit -14"-18" allowed from top of water meter to top of lid -one joist hanger on the back patio is missing nails -all fees must be paid _TCO expiration 05-30-2023
---	------	---

Corrective Action Required:

2	Misc	TCO HAS EXPIRED PERMIT NOW IN NOTIC OF VIOLATION. Mitchell Schwarz 06/26/2023 10:45 AM
---	------	---

