

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216531  
Address: 1708 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Friday, June 30, 2023

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none"><li>- Dishwasher is not on a GFCI breaker</li><li>- House to garage door self closing hinge is not working</li><li>- Top is A/C disconnect needs to be sealed</li><li>- tighten every all through deck post nuts</li></ul>
---	--------------------------	--

**Comments:**