

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20215017
Address: 126 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Friday, June 30, 2023
Inspected By: Robb Popp
Expiration Date: 7/30/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Pending	

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Obtain an irrigation permit
- Label non gfci outlet at sump
-
- Secure A/C whip at compressor within 12" of disconnect
- Provide splash pads |
|---|------|--|