

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220428
Address: 3541 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Monday, July 03, 2023

Corrective Action Required:

2	Miscellaneous Correction	<ul style="list-style-type: none">- address numbers are above light and will not illuminate correctly- Exterior garage lights need to be sealed along the top- Kitchen backsplash electrical plugs need spark rings installed- Basement bathroom needs a electrical outlet within 3 feet of the sink- Handrail in basement is not installed- Gas line needs to be bonded- Seal boards at ceiling in interior garage- Sod splash pads are not installed- Exterior penetrations need to be sealed- Slump pump drain needs to extend 36 inches from foundation
---	--------------------------	--

Comments: