



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20111755, Building Permit - Commercial
Address: 1223 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Passed	Monday, June 20, 2011

Above Ceiling Inspection	Khanh Nguyen	Partial	Monday, June 20, 2011
---------------------------------	--------------	---------	-----------------------

Corrective Action Required
1 MISC

SUPPORT EMT CONDUIT NEAR MECHANICAL (MAX. SPAN WITHOUT SUPPORT IS 10 FT)

Comments: OK TO DROP CEILING TILES AND ROCK THE WALL