

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215979
Address: 110 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Friday, July 07, 2023

Corrective Action Required:

1	Misc	7/7/23 -Not ready for occupancy inspection, list incomplete -Complete electrical in kitchen, label dedicated non gfci in garage, install non combustibile attic access cover, adjust garage door to self close and latch **OK to store items in garage per conversation with contractor, DO NOT OCCUPY OR COVER INSPECTION ITEMS -RP
---	------	---

Comments: