

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225143
Address: 2306 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, July 10, 2023

Corrective Action Required:

1 Misc

-uncover covered patio and address notched ceiling joists. Leave uncovered for inspection **Header off over-notched ceiling joist

-address wall space to ceiling space at stairwell **Fb stair well wall space from horizontal space every 10' and to under stairs

Comments: