

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221108
Address: 3104 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, July 10, 2023

Corrective Action Required:

1	Misc	TCO expired 7/7/23 Submit TCO extension request form -landing at bottom of stairs at deck must be 36" in the direction of travel (R311.7.6) -2 1/2" through bolts at each deck post to beam connection (R507.5.1)
---	------	--

Comments: