

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220755
Address: 2822 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, July 10, 2023

Corrective Action Required:

1	Misc	-Counter top Outlet spacing at basement wet bar to be code compliant see figure E 3901.4.1 of the 2018 irc
---	------	------------------------------------------------------------------------------------------------------------

Comments: