

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223259
Address: 2785 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Shawn Hoffman	Failed	Tuesday, July 11, 2023

Corrective Action Required:

1	Misc	- Uncover man hole - Lower water meter in pit to 14"-18" from rim of pit.
---	------	--

Comments: