

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220490
Address: 2022 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, July 11, 2023

Corrective Action Required:

2 Misc

- provide attic access above single car garage and at 2nd story
- fire block plumbing chase to furr down in garage
- fire block NW wall into furr down
- CSPF NW sunroom wall to plans
- hold down at beam NW sunroom wall per plans
- provide way to view above cover deck
- complete gas line install at fireplace
- strike plate for wires as needed at top plate left of fireplace
- (3) 2x6 under triple lvl above stairs 2nd floor hall end
- fire block vertically to horizontally every 10' at stairwell wall
- all anchor bolt to be in the middle 1/3 of sill plate and tight
- will check back garage wall anchor bolts at time of reinspection

Comments: