CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20225301Address:400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	on:	Inspector:	Outcome:	Date:
Water Se	ervice Inspection	John Jackson	Passed	Tuesday, July 11, 2023
Informational:				
1	Misc 07/11/23 Tuesday JMJ (Questec)			
		3" water main install to the building completed from work done approximately 6 months ago. 3"gate valve to 2' of 3" pipe, 90 deg bend to of 3" pipe, 90 deg bend to approximately 10' of 3" pipe (4' outside & 6' inside). A 90 deg bend turn to the inside 3" butter fly valve and flange on end. All work appears to be acceptable.		pipe, 90 deg bend to 3.5' pe (4' outside & 6'

Comments: