

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20215636  
Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 2</b>	Devon Perry	Passed	Tuesday, July 11, 2023

Informational:

1	Misc	5-24-23 DP. Sample #2 on water line 1 was taken and dropped off. 5-25-23 DP. Sample #2 on water line 1 passed.  6-30-23 DP. Sample 2 on water line 2 was taken  7-3-23 DP. Sample 2 on water line 2 passed.
---	------	--

**Comments:**