

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222753  
Address: 2226 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, July 11, 2023

Corrective Action Required:

1	Misc	-address pending driveway inspection -address pending pier inspection -sod -splash block and sump pump discharge to extend 36" from foundation -outlet at basement wet bar to be with 24" of sink -set screw sheered off at water anti syphon device -water heater relief valve discharge pump to high off ground see P2804.6.1(10) of the 2018 irc -bring hydrant valve lid and ring to grade
---	------	---

**Comments:**