

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224901
Address: 2602 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, July 12, 2023

Corrective Action Required:

1	Misc	Address pending driveway and sidewalk inspection -sod -splash block and sump pump discharge to extend 36" from foundation -Lock out for oven breaker -complete water heater wiring -address deck post to beam connections
---	------	--

Comments: