

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215979
Address: 110 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Devon Perry	Passed	Thursday, July 13, 2023

Informational:
1 Misc 6-27-23 DP. Contractor had sw formed, aggregate compacted and cross slopes were in compliance but conditions can change. Approved to pour

7-13-23 DP. SW was poured, cross slopes are in compliance. Passed.

Comments: