

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222753
Address: 2226 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Thursday, July 13, 2023

Corrective Action Required:

1	Misc	-Establish erosion control methods before any further inspections -address pending pier inspection -sod -splash block and sump pump discharge to extend 36" from foundation -outlet at basement wet bar to be with 24" of sink per IRC E3901.4 / NEC 210.52(c) -water heater relief valve discharge pump to high off ground see P2804.6.1(10) of the 2018 irc -bring hydrant valve lid and ring to grade
---	------	--

Comments: