

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231491  
Address: 1524 NE PARK SPRINGS TER, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, July 13, 2023

Corrective Action Required:

1	Misc	-Support lvl hip rafter at ridge above doorway to pocket office
		-Strap master bathroom wall top plates lapped less than 24"
		-Fb basement wall space from soffit; Fb basement bathroom wall from soffit
		-Fill in void at basement door hinges
		-S-trap not allowed for master shower

**\*\*OK TO INSULATE**

**Comments:**