

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20225745  
Address: 3219 SW ENOCH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Monday, July 10, 2023

Corrective Action Required:  
2 Misc

- fire block top plate penetration at double car garage
- uncover covered garages for nailing inspection
- top plate penetration to be sealed rear garage wall
- protect NM wire within 6' of attic access
- seal dryer vent top plate penetration
- primary bath toilet top plate penetration
- secure gas line at fireplace
- missing nails in hangers right of stairs in basement
- anchor bolts to be in the middle 1/3 of sill plate in basement throughout
- fireblock wall space to ceiling space in rec room left of slider at furr out
- strap top plate penetrations for pex and dwv in bed 4/5 bath
- complete closet framing for bed 4
- fire block bed 4 W wall to ceiling space
- fire block dead space at shared bath into furr down
- secure pex in basement shared bath
- missing truss hangers above primary closet and bath
- uncover covered front porch to verify hangers
-

**Comments:**