CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231176

Address: 2127 SW OSAGE DR, LEES SUMMIT, MO 640822129 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Kyle Beard Failed Friday, July 14, 2023

Residential

Corrective Action Required:

1 Miscellaneous 2127 Correction

- address numbers are higher than the exterior lighting and will not illuminate correctly
- Kitchen backsplash GFCI will not reset
- Hot water expansion tank is in contact with electrical whip
- Bushing needs to be installed at the top of the conduit for the sump pump
- Sewer line bracket is not supporting the PVC sewer line
- One support bracket for the 2 inch sewer line is not supporting the PVC sewer line
- Washer and dryer is missing the anti water hammer device
- Master bathroom is missing its shower fixtures
- Back porch electrical receptacle is loose from the wall
- Garage to house door is missing its seal
- Top of threshold to first step down at garage stairs is 8 1/4 in height, code allows only 7 3/4 inch riser height
- Sod is not installed
- Sump pump extension is not installed
- Splash pads are not installed

- House to garage door will not close and lock correctly
- Stove anti tip bracket is not working
- Washer and dryer do not have a anti water hammer device installed
- Exterior rock is not installed at the garage doors
- Sump pump extension line is not installed
- Sod is not installed
- Splash pads are not installed

Comments: