



**LEE'S SUMMIT**  
MISSOURI

**CODE MODIFICATION REQUEST**

BUILDING/STRUCTURE NAME: Paragon Star - Soccer Fields - South Restroom Building

PREMISE ADDRESS: 1401 NW River Rd, Lee's Summit, MO 64081

PERMIT NUMBER (if applicable): PRCOM20230899

OWNER'S NAME: Paragon Star

TO: Director of Development Services

In accordance with the Lee's Summit Building Code, I wish to apply for a modification to one or more provisions of the code as I feel that the spirit and intent of the Lee's Summit Building Code are observed the public health, welfare and safety are assured. The following articulates my request for your review and action. (NOTE: ATTACH ANY ADDITIONAL INFORMATION NECESSARY)

Type of Request: ( ) Design ( ) Construction

Our request is to provide 2" of an R-5 insulation product to infill the CMU cores of our exterior wall assembly (goal to hit R-10). It is our professional opinion that this is in the spirit of the code intent and will be more than adequate for the unoccupied nature of this accessory restroom structure.

SUBMITTED BY:

NAME: Jessica Reed-Shultz

ADDRESS: 8787 Renner Blvd, Suite 100

CITY, STATE, ZIP: Lenexa, KS 66219

( ) OWNER ☒ OWNER'S AGENT

Tel.# 913-498-1550 x 112

SIGNATURE: 

Plan Review / Inspections Manager:

(x) APPROVAL

( ) DENIAL

SIGNATURE: \_\_\_\_\_ DATE: 4/13/2023

Director of Development Services:

( ) APPROVED

( ) DENIED

SIGNATURE: \_\_\_\_\_ DATE: \_\_\_\_\_

COMMENTS \_\_\_\_\_

**A COPY MUST BE ATTACHED TO THE APPROVED PLANS ON THE JOB SITE**