



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20112117, Building Permit - Commercial
Address: 910 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Failed	Wednesday, June 22, 2011

Corrective Action Required
1 MISC

CORRIDOR WALL NOT OK TO CLOSE. SEE RATED ASSEMBLY.

Rated Assembly Inspection	John Borns	Not Ready	Wednesday, June 22, 2011
----------------------------------	------------	-----------	--------------------------

Partial Correction
1 MISC

OK TO MUD, TAPE, AND FIRE-SEAL (PER DRAWING) 5/8" TYPE X
GWB AT EAST WALL WEST FACE

Corrective Action Required
2 MISC

4" MINERAL WOOL FIRE-SEAL NOT FOUND IN PLACE PER
DRAWING DETAIL (6) AT EAST WALL EAST FACE

Comments: