



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20111755, Building Permit - Commercial
Address: 1223 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Wednesday, June 22, 2011

Corrective Action Required

1	MISC	PROTECT PLUMBING WITHIN 1.5" OF STUD SURFACE
---	------	--

Above Ceiling Inspection	Khanh Nguyen	Passed	Wednesday, June 22, 2011
---------------------------------	--------------	--------	--------------------------

Comments: