

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20232009
Address: 2141 SW OSAGE DR, LEES SUMMIT, MO 640822139 SW OSAGE DR, LEES
SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed - Stop Work	Monday, July 17, 2023

Corrective Action Required

1	Miscellaneous Correction	All rough could not be completed. Under ground plumbing was never scheduled or inspected. A stop work order on this permit has been placed. 07/17/2023. KBEARD
---	--------------------------	---

Comments: