



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100137, Building Permit - Commercial
Address: 1255 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|-------------------------|
| Sewer Service Inspection - Commercial | John Borns | Partial | Thursday, June 23, 2011 |

Partial Correction
1 MISC

OK TO COVER WHEN READY 4" PVC SANITARY SEWER SERVICE LINE FOLLOWING SEGMENTS: FROM GREASE INTERCEPTOR 120' SOUTH / SOUTHWEST / WEST; CONTINUED 30' WEST & DROPPED BELOW INTERSECTING STORM SEWER ELEVATION; EXTENDED TO WITHIN 2' OF CONNECTION @ MAIN, WHICH IS SUBJECT TO APPROVAL BY PUBLIC WORKS DEPT

Comments: