

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223034
Address: 2816 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, July 18, 2023

Corrective Action Required:

1 Misc

- window fall protection in bedroom at garage entry
- paint gas line under deck
- address post to beam connection SW post
- address pending pier inspection
- sod and landscaping
- splash blocks and sump pump discharge to extend 36" from foundation
- uncover covered sewer tracer wire
- well check water meter at time of sod

Comments: