

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220428
Address: 3541 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Robb Popp	Failed	Wednesday, July 19, 2023

Corrective Action Required:

1	Misc	-Grade at back of house does not have proper slope -Must have min 6" in first 10' away from foundation for proper drainage
---	------	-------------------------------------------------------------------------------------------------------------------------------

Comments: