

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220522  
Address: 3522 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Not Ready	Wednesday, July 19, 2023

Corrective Action Required:

1	Misc	Sod to siding must be at least 6 inches in height. Sod must have a 2 percent slope away from the foundation. **MISSING SOD AT DECK NOT READY
---	------	---

**Comments:**