

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231576
Address: 1029 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, July 19, 2023

Corrective Action Required:

2	Misc	Over notched stud at garage at sill plate
		- Complete vent in powder room
		- Block return air in to soffit in pantry
		- Fire block kitchen wall and the other end around pantry soffit
		- Address over bored joist above kitchen island
		- Solid block cantilever at front porch
		- Fire block ceiling to wall in master bedroom
		- Missing studs master bedroom
		- Bathroom vents missing upstairs
		- Address cut joint by furnace

Comments: