

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20215798
Address: 1609 SW 27TH ST, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed - Stop Work	Thursday, July 20, 2023

Corrective Action Required

1	Misc	-address header size in master bath not to plans (engineer) -provide engineering floor joist city stamped plans on site and uploaded (not uploaded or stamped) -address lvl's drilled through above bed 4 per 502.8.2 (engineers) -address l joist above basement bed bath sinks for cut drain above -fireblock -provide support for furr down in family room to floor joists above
---	------	--

Corrective Action Required

2	Misc	-Provide city stamped plans on site
---	------	-------------------------------------

Corrective Action Required

3	Misc	Stop work issued until outstanding items are addressed
---	------	--

Comments:

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201