

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20216461  
Address: 3132 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	Mitchell Schwarz	Failed	Friday, July 21, 2023

Informational:	
1 Misc	shade structure piers okay to pour
Corrective Action Required:	
2 Misc	light pole bases poured without inspection. provide third party inspection report and revise plans.

**Comments:**