



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110420, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Friday, June 24, 2011

Partial Correction
1

OK TO COVER WHEN READY WALLS + SOFFITS FROM WEST
SOFFIT BRIDGE EAST TO CORRIDOR WALL;

Comments: BEFORE COVERING INSTALL THREE BOCA PLATES AT PVC PLUMBING PIPING AS DISCUSSED; ALSO ISOLATE COPPER WATER PIPE FROM FRAMING AT TWO LOCATIONS; ALSO PROVIDE BACK-UP FOR ELECTRICAL BOX STAND-OFFS @ 4 LOCATIONS.