

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231576
Address: 1029 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, July 24, 2023

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | - Block return air in to soffit in pantry (now blocking return air from stud to joist space)
- Address over bored joist above kitchen island |
|---|------|---|

Comments: