

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223894
Address: 1046 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, July 26, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Sidewalk inspection pending- Driveway inspection pending- Obtain an irrigation permit and submit back flow certification- Provide sod- Provide splash pads 36" away from foundation- Seal all exterior penetrations- Lower sewer trace wire to grade
---	------	--

Comments: