CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20232379 Address: 2070 NW LOWENSTEIN DR, Unit:IR, LEES SUMMIT, MO 640812070 NW LOWENSTEIN DR, Unit:A, LEES SUMMIT, MO 640812070 NW LOWENSTEIN DR, Unit:B, LEES SUMMIT, MO 640812070 NW LOWENSTEIN DR, Unit:C, LEES SUMMIT, MO 640812060 NW LOWENSTEIN DR, LEES SUMMIT, MO 640812070 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Water Service Inspection		Devon Perry	Partial	Wednesday, July 26, 2023
Informatio	onal:			
1	Misc	doesn't seem to be there. want to use tee's for wate 7-19-23 DP. Contractor dug When they removed the d After pumping the water of them add a megalug on th duckbilled these together	17-23 DP. The 8" stub that is suppose to come across the private drive besn't seem to be there. We need to figure that out first. Also, we do not ant to use tee's for water services. These will be required to be taps. 19-23 DP. Contractor dug down to find the 8" stub that goes across to Lot 5. Then they removed the dirt the valve slipped off causing a water break. If the pumping the water down, the valve wasn't installed properly. I had been add a megalug on the pipe and megalug on the valve. Then they uckbilled these together. After a valve they installed a 8" 90* and 1 stick of ductile that runs to the south. This extension will be used for the 4 taps that is needed.	
		7-25-23 DP. Contractor chlorinated the stick of pipe that was added.		
			as flushed. Will be ready for pressure testing needed w	

Comments: